

**JURUPA COMMUNITY SERVICES DISTRICT
RIVERSIDE, CALIFORNIA**

ADDENDUM NO. 1

**TO THE PLANS AND SPECIFICATIONS FOR
WELL NO. 6 RETROFIT AND SITE IMPROVEMENTS AND
WELL 14 AND 15 PUMP-TO-WASTE SYSTEM [D.P.N. 3359]**

Bidders are advised that the plans and specifications for the above referenced contract are hereby amended in the following manner and the following manner only:

A. GENERAL

1. All provisions of this Addendum No. 1 are hereby incorporated into the Contract Documents and bidders shall account for all provisions pursuant to this Addendum No. 1 in submitting their bid proposals. **EACH BIDDER SHALL INCLUDE A DATED AND SIGNED COPY OF THIS ADDENDUM NO. 1 WITH HIS SEALED BID PROPOSAL.**
2. Furnish and install additional 3' x 5' SCE pull box per SCE Standards for service to Well 6 facilities, to be installed in parkway area, just north of Well 6 facilities. Include costs within Bid Item No. 108.

B. SPECIFICATIONS

1. The following Section entitled "CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD, SANTA ANA REGION PERMIT" shall be made part of the Special Requirements (See Attachment "A").
2. On Section 4 entitled "Contract Completion Schedule", 2nd paragraph, Phase 1, add "METAL BUILDING SHALL ALSO BE REMOVED BEFORE OCTOBER 1, 2010."
3. On Section 9 entitled "Data to be Submitted by Contractor" add the following to the list of the minimum required submittals: "Submit disinfection and flushing procedures for Well No. 6".
4. In the Technical Specifications, 2nd page of the Table of Contents, delete "**DIVISION 13**" in its entirety.
5. On Part 4 entitled "Execution", Paragraph 4.01 entitled "Pumping Unit – Pump Installation Requirements", Page 10 of Section 15162 entitled "Deep Well Vertical Turbine Pumps" of the Technical Specification, delete "5. Pre-approved equal" and add "5. Southwest Pump and Drilling" and "6. Pre-approved equal".

6. In the Contract and Contract Appendix of the Specifications, Riverside County shall be named additionally insured for all insurance requirements in addition to currently named insured and additionally insured.

C. DRAWINGS

1. On Sheet 6 of 26 entitled "Emergency Standby Generator Foundation Plan and Details", for Detail 2 entitled "Concrete Pad to A.C. Paving Transition Detail", add the following note "5. OVER EXCAVATE AND RECOMPACT EXISTING GROUND A MINIMUM OF 12" AT 90% RELATIVE COMPACTION, PROVIDE ADDITIONAL FILL OR REMOVE AND DISPOSE EXCESS SPOILS AS REQUIRED TO MEET PROPOSED GRADES."
2. On Sheet 9 of 26 entitled "Block Wall and Gate Details, and Miscellaneous Details", for Detail 5 entitled "Gate Rail Guide Details", replace callout " HSS 6"x6"x1/4" BRACKETS " with " HSS 6"x2"x1/4" BRACKETS ".
3. On Sheet E11 of 26 entitled "CL2 Injection Control Panel Control Schematic and Elevations", the Control Transformer is not required.



By: *Sinnaro Yos* 7/28/10
 Sinnaro Yos date
 P. E. 68607

By: _____
 (Bidder's Company Name)

Date Received by Bidder: _____
 (Bidder's Signature)

 (Type or Print Name)

**BIDDER SHALL INCLUDE A SIGNED COPY OF THIS
 ADDENDUM NO. 1 WITH THE BID PROPOSAL.**

Attachment "A"
California Regional Water Quality Control Board,
Santa Ana Region Permit

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD,
SANTA ANA REGION PERMIT

Contractor shall channel (using sandbags or other means) flushing flow. Contractor shall protect all property from flooding and other damage during flushing operations. Contractor shall post "flooding ahead" signs in streets as required and as directed. Because of demand on existing water system, Counties may require Contractor to flush the pipeline over several days, in the evenings, weekends, or holidays.

Contractor shall not allow any discharges from the construction site which may have an adverse effect on receiving waters of the United States.

Contractor shall, at his expense, obtain a discharge permit from the California Regional Water Quality Control Board, Santa Ana Region (Regional Board) for discharge of water from trench dewatering, line flushing, and testing operations. A copy of said discharge permit shall be provided to the District. Contractor shall comply with conditions therein and perform the monitoring required. If the Regional Board determines that a discharge permit is not required for said work, then the Contractor shall comply with any and all applicable criteria and conditions established by the Regional Board, including compliance with the requirements of the General Water Discharge Requirements for Discharges to Surface Waters which pose an insignificant De Minimus threat to water quality (Order No. 98-67).

Order No. 98-67 includes submittal of a Notice of Intent and a waste discharge report to the Regional Board. In addition, Template Monitoring and Reporting Program No. 98-67, appended to Order No. 98-67, includes the following monitoring and reporting requirements:

(A) Estimate and report daily discharge flow, collect samples of each discharge and have them analyzed for the 8 parameters listed on Pages 2 and 3 of the Template Monitoring and Reporting Program No. 98-67. All samples shall be representative of the waste discharge under conditions of peak load.

All sample collection, sample preservation, and analyses shall be performed in accordance with the latest edition of "Guidelines Establishing Test Procedures for Analysis of Pollutants" promulgated by the U. S. Environmental Protection Agency (40 CFR 136). All samples analyses shall be performed by an analytical laboratory certified by the California Department of Health Services to perform such analyses.

(B) Report any discharge which is in violation of the discharge specifications (Order No. 98-67) to the Regional Board, Santa Ana Region within 24 hours.

(C) Notify the Regional Board 5 days before commencing any discharge.

(D) Prepare monthly monitoring reports for submittal to the Regional Board. The reports shall include:

(a) Results from all analyses for the previous month.

(b) Daily flow data.

(c) A report detailing Contractor's compliance or noncompliance with Order No. 98-67 and the discharge authorization letter.