



NOTES:

1. TYPICAL CASE SHOWN IS FOR NEW WATER PIPELINE AND EXISTING SEWER LINE.
2. THERE SHALL BE NO JOINTS ALLOWED ON WATER PIPELINE WITHIN 10' EITHER SIDE OF EXISTING SEWER LINE EXCEPT FULLY WELDED (DOUBLE PASS) JOINTS.
3. THIS STANDARD SHALL APPLY TO EXISTING SEWER MAIN LINE CROSSING AS WELL AS EXISTING SEWER LATERALS.
4. WATERLINE CROSSING UNDER A SEWERLINE SHALL MEET ALL DIVISION OF DRINKING WATER, STATE WATER RESOURCES CONTROL BOARD REQUIREMENTS.

# JURUPA COMMUNITY SERVICES DISTRICT

SCALE: NONE

DATE: SEPTEMBER 2020

APPROVED BY: *Sinnaro Yos*  
Sinnaro Yos, P.E. C68607

## TYPICAL WATERMAIN CROSSING UNDER SEWER LATERAL

ALBERT A. WEBB ASSOCIATES  
CONSULTING ENGINEERS

RIVERSIDE

CALIFORNIA

DRAWING NO.

### A-10

W.O. 19-0248

REV.