



**OPTIONS**

- (A) NO JOINTS WITHIN 10' OF STORM DRAIN, OR;
- (B) IF JOINTS MUST FALL WITHIN 10' OF STORM DRAIN, JOINTS SHALL BE FULLY WELDED, DOUBLE PASS MINIMUM.

NOTE: JOINTS WITHIN 10" OF STORM DRAIN OUTER WALL MUST BE DOUBLE-PASS WELDED

| ITEM | DESCRIPTION  |
|------|--|
| ①    | FLANGED CML & CMC STD. WT. STEEL WATERMAIN                       |
| ②    | FLANGED 11.25°, 22.5°, 45° CML & CMC STD. WT. LONG RADIUS ELBOW. |
| ③    | FULLY-RESTRAINED MJxFL PVC/STEEL TRANSITION COUPLING             |
| ④    | PVC C909 WATERMAIN   |
| ⑤    | SLURRY BACKFILL (2-SACK CEMENT SLURRY)                           |

# JURUPA COMMUNITY SERVICES DISTRICT

|  |   |              |
|--|---|--------------|
| SCALE: NONE                                  | <b>WATER MAIN CROSSING<br/>UNDER STORM DRAIN</b>  | DRAWING NO.  |
| DATE: SEPTEMBER 2020                         | ALBERT A. WEBB ASSOCIATES<br>CONSULTING ENGINEERS | <b>A-13</b>  |
| APPROVED BY:<br><br>Sinnaro Yos, P.E. C68607 | RIVERSIDE CALIFORNIA                              | W.O. 19-0248 |

REV.