



NOTES:

1. FIELD JOINTS MAY BE FLANGED OR WELDED, BUT SHALL NOT PERMANENTLY IMPAIR LINING OR COATING OF PIPE.
2. UPON APPROVAL OF DISTRICT, SCHED. 80 P.V.C. PIPE MAY BE USED FOR VENT IN LIEU OF 10 GA. STEEL.

JURUPA COMMUNITY SERVICES DISTRICT

SCALE: NONE	STANDARD VENT INSTALLATION	DRAWING NO. A-9
DATE: SEPTEMBER 2020	ALBERT A. WEBB ASSOCIATES CONSULTING ENGINEERS	
REV. APPROVED BY: Sinnaro Yos, P.E. C68607	RIVERSIDE CALIFORNIA	W.O. 19-0248