


(*) 18" THK. CONC. PAD AT FINISH GRADE WHEN VALVE IN GRASS, GRAVEL OR UNIMPROVED AREAS

SEE NOTE #2 BELOW

2" SQ. OPERATING NUT SET 24" BELOW FINISHED SURFACE



CENTERING RING DETAIL

ADJUSTABLE CENTERING RING



VALVE CAP DETAIL

A.W.W.A. C-509 (LATEST) FLANGED RESILIENT SEAT GATE VALVE, 200 W.O.G. I.B.B.M. N.R.S. "O"RING SEAL, 2" SQ. OPERATING NUT ALL FERROUS SURFACES SHALL BE EPOXY COATED INSIDE AND OUT: PER OWNER SPECIFICATION. (FOR C-909 PVC USE FLANGED ADAPTER BY GRIPTYPE (OR APPROVED EQUAL) OR SLIP-ON VALVE)

NOTES:

1. VALVE MARKER PER STD. NO. A-3 TO BE INSTALLED AS DIRECTED BY THE DISTRICT.
2. CLASS "B" CONCRETE PAD, 20" SQ. POUR AGAINST WELL COMPACTED EARTH, 90% MIN. RELATIVE COMPACTION AT FINISHED GRADE IN NON-PAVED AREAS.

JURUPA COMMUNITY SERVICES DISTRICT

SCALE: NONE

DATE: SEPTEMBER 2020

APPROVED BY:

Sinnaro Yos
Sinnaro Yos, P.E. C68607

GATE VALVE INSTALLATION

ALBERT A. WEBB ASSOCIATES
CONSULTING ENGINEERS

RIVERSIDE

CALIFORNIA

DRAWING NO.

B-1

W.O. 19-0248