



## MANIFOLD DESIGN GUIDELINES <sup>1</sup>

MANIFOLD DIA.	MAXIMUM NO. OF 2" (OR SMALLER) WATER SERVICES
4"	4
6"	8

1. SIZING SHOULD BE VERIFIED BY THE DESIGN ENGINEER BASED UPON THE SPECIFIC AVAILABLE PRESSURES IN THE WATERMAIN AND THE ON-SITE WATER SERVICE PRESSURES REQUIRED.
2. SERVICE MANIFOLD SHALL BE APPROVED BY DISTRICT, AND WILL BE ALLOWED ONLY WHERE MULTIPLE INDIVIDUAL SERVICE LATERALS ARE NOT PHYSICALLY POSSIBLE.
3. ALL DUCTILE IRON PIPE AND FITTINGS SHALL BE CEMENT MORTAR LINED.
4. MANIFOLD SHALL NOT BE INSTALLED WITHOUT THE DISTRICT'S WRITTEN AUTHORIZATION.

# JURUPA COMMUNITY SERVICES DISTRICT

SCALE: NONE

DATE: SEPTEMBER 2020

APPROVED BY:

*Sinnaro Yos*  
Sinnaro Yos, P.E. C68607

## SERVICE MANIFOLD DETAIL

ALBERT A. WEBB ASSOCIATES  
CONSULTING ENGINEERS

RIVERSIDE

CALIFORNIA

DRAWING NO.

**D-8**

W.O. 19-0248

REV.