



NOTES:

1. ALL BACKFILL SHALL BE PLACED IN ACCORDANCE WITH THE SPECIFICATIONS.
2. O.D. = OUTSIDE DIAMETER OF BELL.
3. Bc = OUTSIDE DIAMETER OF PIPE BARREL.
4. W = 10 INCHES MAXIMUM.
5. CONCRETE SHALL BE ALLOWED TO DEVELOP SUFFICIENT STRENGTH BEFORE BACKFILLING.
6. WHEN GROUND WATER ENCOUNTERED, ENCASE THE ROCK BEDDING IN FILTER FABRIC.

JURUPA COMMUNITY SERVICES DISTRICT

SCALE: NONE	GENERAL BEDDING DETAILS	DRAWING NO.
DATE: SEPTEMBER 2020		S-1
APPROVED BY: Sinnaro Yos, P.E. C68607	ALBERT A. WEBB ASSOCIATES CONSULTING ENGINEERS	
REV.	RIVERSIDE CALIFORNIA	W.O. 19-0248