



GENERAL NOTES:

1. NO TAPPING OF EXISTING SEWER MAINS WILL BE ALLOWED WITHOUT SPECIFIC APPROVAL BY DISTRICT. IF APPROVAL IS GRANTED, WORK SHALL BE PERFORMED UNDER CONTINUOUS DISTRICT INSPECTION.
2. MAXIMUM SEWER MAIN SIZE FOR TAPPING SHALL BE 15" DIA., UNLESS OTHERWISE APPROVED BY DISTRICT.
3. WIRE BRUSH 1/4" IN FROM THE END OF PIPE. AFTER WIRE BRUSHING, APPLY A TWO PART EPOXY TO SEAL THE ENDS OF THE PIPES.
4. USE DISTRICT APPROVED TWO PART EPOXY J-B WELD NO. 8280 SPEC. ON EXPOSED HONEYCOMB ENDS AND ALLOW TO SET PRIOR TO ASSEMBLY.

# JURUPA COMMUNITY SERVICES DISTRICT

SCALE: NONE	<b>SEWER LATERAL TAPPING TO EXISTING TRUSS MAIN</b>	DRAWING NO. <b>S-18C</b>
DATE: SEPTEMBER 2020	ALBERT A. WEBB ASSOCIATES CONSULTING ENGINEERS	W.O. 19-0248
REV. APPROVED BY: Sinnaro Yos, P.E. C68607	RIVERSIDE CALIFORNIA	