



DEPTH "D"	
FOR PIPE DEPTH < 14'	"D" = 6"
FOR PIPE DEPTH > 14'	"D" = 12"

**CLASS "I"**  
 DEPTH > 14 FEET  
 PVC SDR 26 ONLY

NOTES:

1. ALL BACKFILL SHALL BE PLACED IN ACCORDANCE WITH THE SPECIFICATIONS.
2. O.D. = OUTSIDE DIAMETER OF BELL.
3. Bc = OUTSIDE DIAMETER OF PIPE BARREL.
4. WT = TRENCH WIDTH MEASURED AT TOP OF PIPE.
5. W = 10" MAXIMUM.
6. FOR PIPES DEEPER THAN 8', LOCATOR WIRE SHALL BE INSTALLED ABOVE THE PIPE, AT AN 8' MAXIMUM DEPTH.
7. ENCASE CRUSHED ROCK WITH DISTRICT APPROVED FILTER FABRIC WHEN ENCOUNTERING GROUNDWATER.

**JURUPA COMMUNITY SERVICES DISTRICT**

SCALE: NONE		<b>GENERAL BEDDING DETAILS</b> <b>FLEXIBLE GRAVITY PIPE</b>	DRAWING NO.
DATE: SEPTEMBER 2020			<b>S-2</b>
REV.	APPROVED BY: <i>Sinnaro Yos</i>	ALBERT A. WEBB ASSOCIATES CONSULTING ENGINEERS	
	Sinnaro Yos, P.E. C68607		RIVERSIDE CALIFORNIA