

SAWPA/WMWD—BRINE LINE
Table 1 DISCHARGE LIMITATION TABLE

POLLUTANT	LOCAL NON-DOMESTIC WASTEWATER LIMITATIONS	
	DAILY MAXIMUM	UNITS
pH ¹	6.0 - 12.0	S.U.
Ammonia	Report	mg/L
Biochemical Oxygen Demand (BOD) ²	12,000 ³	mg/L
Total Suspended Solids (TSS) ²	No Limit	mg/L
Hardness - Total	No Limit	mg/L
Total Dissolved Solids (TDS)	No Limit	mg/L
Volatile Suspended Solids (VSS)	No Limit	mg/L
Arsenic	2.0	mg/L
Cadmium	1.0	mg/L
Chromium - Total	20.0	mg/L
Copper	3.0	mg/L
Lead	2.0	mg/L
Mercury	0.03	mg/L
Molybdenum	2.3	mg/L
Nickel	10.0	mg/L
Selenium	3.9	mg/L
Silver	15.0	mg/L
Zinc	10.0	mg/L
Cyanide - Total	5.0	mg/L
Sulfide -Dissolved	0.5	mg/L
Sulfide - Total	5.0	mg/L
Oil/Grease - Mineral/Petroleum ⁴	100.0	mg/L
Fats, Oils, and Grease (FOG) ⁴	500.0	mg/L
1,4-dioxane	1.0	mg/L
Pesticides ⁵	0.01	mg/L
Polychlorinated Biphenyls (PCBs) ⁶	0.01	mg/L

Notes to Table 1:

1. pH sample shall be taken at each sampling event and measured using a calibrated pH meter.

2. Strength Based Surcharges apply to BOD & TSS.

3. The BOD Limit of 12,000 mg/L BOD is a Best Management Practices Requirement that applies to permitted users with flow volumes greater than 5,000 gpd.

4. The same sample shall be analyzed for both Polar (FOG) and Non-Polar (Oil & Grease-Mineral/Petroleum) using EPA Method 1664A.

5. Pesticides of concern are as follows: Aldrin, -BHC –BHC, -BHC Chlordane, 4,4'-DDD, 4,4'DDE, 4,4'- DDT, Dieldrin, Endosulfan I, Endosulfan II, Endosulfan Sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, Toxaphene.

6. Polychlorinated Biphenyls of concern are as follows: PCB-1016, PCB-1211, PCB-1232, PCB-1242, PCB-1248, PCB-1254, and PCB-126