

BASIC SPECIFICATIONS

SECTION F

RECYCLED WATER PIPELINE MATERIALS SPECIFICATIONS

1. GENERAL

A. Alternate Pipeline Materials

Where alternate pipeline materials are allowed by the District, the Contractor shall select such materials and construction methods as will result in a satisfactory completed project. All pipe materials shall be new and unused unless otherwise specified. Materials and strength of pipe shall be as shown on the plans or as specified herein.

B. Contractor Furnished Materials

The Contractor shall furnish (excepting materials specifically listed in the Special Requirements to be furnished by the District) and install all pipe, fittings, supports, bolts, nuts, gaskets, jointing materials, appurtenances, auxiliary piping and connections to equipment in accordance with the drawings and specifications, all as required for a complete and workable piping system.

C. Exposed Piping Supports

All exposed piping shall be adequately supported with devices of appropriate design unless otherwise approved by Engineer, the support shall conform to the Standard Drawing No. R/NP-5 or as shown on the Drawings.

D. Piping Sizes

Pipe sizes are nominal inside diameter unless otherwise noted. All sizes and types of pipe are noted on the Drawings, and specified herein. Where pipe is lined, the nominal diameter shall be the inside diameter of the cement mortar lining, except for wrought iron pipe.

E. Dissimilar Metals

All dissimilar metals shall be insulated from one another with approved insulating flange sets or unions.

F. Material Identification

All pipe and fittings delivered to the job site shall be clearly marked to identify the manufacturer's name, material, class, and thickness. All material shall be new and free of blemishes. Acceptance of pipe and accessories by the District will be based on load bearing tests, and inspection of the complete products as specified hereinafter. Acceptance of installed piping will be based on inspection and leakage tests as specified hereinafter.

2. WELDED STEEL PIPE, CML & CMC

Shop fabricated pipe with machine-applied lining and coating, dye-check shop welding performed after hydrostatic testing of cylinders, pipe per AWWA C200, steel plate per ASTM A1011/A1011M, 10 ga. minimum, minimum yield 36,000 psi, cement mortar coating and lining per AWWA C205. Design stress shall not exceed 18,000 psi. Each pipe section shall be provided, prior to delivery, with temporary plastic end covers, with exposed steel shop coated, 40' maximum joint lengths, lap weld bell x plain end spigot, or as indicated on the Drawings and/or Bidding Sheet, including rubber gaskets and gasket lubricant. Pipe furnished herein shall be from an organization which has had not less than ten (10) years successful experience providing pipelines of the type specified.

The minimum steel plate thicknesses utilized for recycled water pipeline shall be as shown below:

**JURUPA COMMUNITY SERVICES DISTRICT
MINIMUM RECYCLED WATER PIPELINE THICKNESS**

Nominal Pipe Diameter	Minimum Cylinder Diameter	Class 150 Minimum Plate Thickness	Minimum Cement Mortar Lining Thickness	Minimum Cement Mortar Coating Thickness
6"	6-5/8" O.D.	0.1345"	1/4"	3/4"
8"	8-5/8" O.D.	0.1345"	1/4"	3/4"
12"	12-3/4" O.D.	0.1345"	5/16"	3/4"
16"	17-3/8" O.D.	0.188"	5/16"	3/4"
18"	19-3/8" O.D.	0.188"	5/16"	3/4"
20"	21-3/8" O.D.	0.188"	5/16"	3/4"
24"	25-3/8" O.D.	0.188"	3/8"	3/4"
30"	31-3/8" O.D.	0.188"	3/8"	3/4"
36"	37-3/8" O.D.	0.188"	3/8"	3/4"

NOTES

1. *Steel thicknesses indicated hereon are minimum; and design steel thickness shall be determined from the pressure imposed (Class, the design stress of the steel and the O.D. of the cylinder). The minimum acceptable yield strength of the steel shall be 36,000 psi. Design stress shall not exceed 18,000 psi regardless of yield strength of steel.*
2. *All materials shall conform with AWWA Specifications C200 (Steel Pipe CML/CMC, Section C205)*

3. DUCTILE IRON RECYCLED WATER PIPE

Ductile Iron Recycled Water Pipe shall be used only where specifically approved by District; and shall comply with ANSI A21.51 rubber gasket push-on type joint bell and spigot, conforming to ANSI A21.11 manufactured in sections of 18 feet or 20 feet. Fittings shall be rubber gasket push-on manufactured in accordance with ANSI A21.10. Where indicated on the Project Drawings, restrained joints shall mean the use of T.R. Flex Pipe as manufactured by U.S. Pipe or approved equal. All ductile iron pipe shall be provided with double polyethylene encasement color purple for the entire length of the pipeline, per AWWA C105.

Unless otherwise specified, the interior of the Ductile Iron Recycled Water Pipe and fittings shall be lined with a uniform thickness of cement mortar "double thickness" then sealed with a bituminous coating in accordance with AWWA C104 (latest). The

outside surfaces of D.I.P. and fittings shall be coated with a bituminous coating in accordance with ANSI A21.6 or ANSI A21.51.

Standard pressure class for Ductile Iron Recycled Water Pipe shall be based on internal pressures and external loadings. Unless otherwise noted, minimum design pressure class shall be 150 psi. Ductile Iron Pipe thickness Class 53 shall be used where flanged or Victaulic-type pipe joints are specified or indicated on the plans.

All service connections made to the Ductile Iron Pipe shall be a brass double service strap type.

4. POLYVINYL CHLORIDE (PVC) PIPE

PVC pipe shall conform to the latest revision of AWWA C909 unless otherwise specified herein.

All rubber rings shall be furnished by the pipe manufacturer. These rubber rings (elastomeric gaskets) shall be manufactured to conform to the requirements of ASTM F477.

This specification includes polyvinyl chloride (PVC) pipe of the following classes/working pressures:

- For Working Pressures up to 150 psi: Class 235
- For Working Pressures up to 200 psi: Class 305

All PVC pipe shall be twenty (20) foot laying lengths and have cast iron outside diameters (C.I.O.D.'s).

AWWA C909 PVC pipe shall be Class 235 minimum or as specified on approved drawings.

PVC pipe shall be installed within one year of its manufactured date. Pipe older than one year shall not be delivered to the construction site.

The District shall require the manufacturer to submit a certificate stating that all pipe has been manufactured and tested in accordance with this specification.

The Contractor shall submit test results showing the physical properties of the materials used in the manufacture of the rubber gaskets, if required by the District. All rubber gaskets furnished under this specification shall be subject to inspection and/or test by the District. Any gasket found to be unsatisfactory by the District shall be immediately replaced by the Contractor, at no expense to the District.

All pipe furnished under these specifications shall be the product of an organization which has had not less than three (3) years of successful experience in the manufacture of pipe of the type specified. The total pipeline shall be the product of one company (or integrated companies) in the business for the design and manufacture of the pipeline materials required herein; unless otherwise approved in writing by the District.

All pipe to be supplied under these specifications must have the following markings on the pipe barrel: Nominal size and O.D. base (for example, 8" C.I.O.D.); dimension ratio number; AWWA pressure class; and manufacturer's name or trademark, production record code and warning label per Section F.19. All pipes shall be the color purple, Pantone 522C.

Joints

Unless otherwise specified or shown, all joints of PVC pipe shall be with elastomeric gasket bell ends. Solvent welded joints will not be allowed. The bell ends shall be an integral thickened bell. The minimum wall thickness of the bell, at any point, between the ring groove and the pipe barrel shall conform to the dimension ratio requirements of AWWA C909.

Pipe Outlets 2 Inches and Smaller

Outlet connections to PVC pipe two (2) inches and smaller shall be bronze service saddles with double bronze straps designed specifically for C.I.O.D. PVC pipe. No single strap saddles or full circle saddles are allowed.

Pipe Outlets Larger Than 2 Inches

Outlet connection to PVC pipe larger than two (2) inches shall be accomplished through the use of ductile fittings.

For outlets to be installed after initial pipeline construction, a tapping saddle may be used subject to advanced written approval by the District.

Ductile Iron Fittings for PVC

Manufacturers of ductile iron fittings proposed to be furnished under the specification must be approved by the District. Ductile iron fittings shall be American made. Manufacturers of ductile iron fittings, which seek District approval, must conform with District procedures concerning approved manufactured materials.

This specification covers ductile iron fittings for use with AWWA C909 polyvinyl chloride (PVC) pipe including tees, crosses, elbows, reducers, and related special fittings. Cast iron fittings are not permitted.

All fittings for use with PVC C909 pipe shall be cast-iron outside diameter (C.I.O.D.) push-on or mechanical joint fittings with the exception of fittings with valves which shall be push-on or mechanical joint by flange. Ductile iron fittings shall be classified as "compact ductile iron fittings" and shall be produced in strict accordance with ANSI/AWWA A21.53/C153. When flanged fittings are specified or required, the fittings shall be ductile iron conforming to AWWA C110/ANSI A21.10, latest.

Unless otherwise specified, the interior of the ductile iron fitting shall be lined with a uniform thickness of cement mortar "double thickness" then sealed with a bituminous coating in accordance with AWWA C104 (latest). The outside surfaces of the DIP fittings shall be coated with NO-OX-ID special protective metal coating and wax.

All ductile iron fittings shall be double polyethylene encased at the time of installation. Double Polyethylene encasement shall be purple in color, Pantone 522C, and installation shall be in accordance with AWWA C105.

Restrained System

All PVC pipe shall be fully-restrained, unless otherwise approved by the District. Restrained joints shall be provided by a clamping ring and an additional ring designed to seat on the bell end of the pipe. The rings shall be connected with T-Head bolts or rods. Restraining devices shall provide full (360 degree) support around the circumference of the pipe. No point loading shall be permitted. Restraint of mechanical joint fittings shall be provided by a clamping ring installed on the PVC pipe and connected to the mechanical joint fitting with T-Head bolts or rods. All restraint devices for PVC pipe shall have a water working pressure rating equivalent to the full rated pressure of the PVC pipe on which they are installed, with a minimum 2:1 safety factor in any nominal pipe size. In

addition, restraining devices shall meet or exceed requirements of UNI-Bell B-13 "Recommended Performance Specification for Joint Restraint Devices for Use with PVC Pipe." Restraining devices shall be approved by the District.

All buried steel parts shall be sand blasted in accordance with the coating manufacturer's technical data sheet for "submerged" service and coated with two-coat epoxy. Epoxy shall be Tnemec Series 66 or approved equal. All bolts and connecting hardware shall be of high strength low alloy material in accordance with ANSI/AWWA C111/A21.11. Buried steel parts shall be covered with grease and wrapped with visqueen in the color purple.

High Deflection Coupling

Pipe joints shall not be pulled at any angle greater than one-half the maximum angle recommended by the pipe manufacturer. If an angle greater than one-half of the maximum angle recommended by the pipe manufacturer is required, install ROMAC Alpha Series Coupling to restrain the joint Minimum Curvature.

Minimum Curvature

Whenever portions of the proposed recycled water construction are to be installed on the radius of a curve, the minimum radius and installation of the pipe shall be in accordance with the manufacturer's recommendations.

Locator Wire

Locator wire shall be installed over all non-metallic pipelines, services, and appurtenances for the purpose of providing a continuous signal path for electronic pipe locators used to determine pipe alignment after installation. Locator wire shall be 14-1 solid insulated copper wire (UF), in a continuous strand, placed on top of pipe and secured with tape. The wire shall be tied to the pipe at 10 foot intervals with plastic adhesive tape. Locator wire shall be brought to the surface in concrete valve boxes as approved by the District at 660 feet maximum on centers and at all appurtenances (i.e. services, air valves, blowoffs, valve cans, etc.), thus providing continuous "looping" between the appurtenances and the recycled water main. If pertinent locations exceed the 660 feet maximum spacing the concrete valve box shall be installed at the edge of right-of-way and the face of curb in front of the box marked with the letters "LW". If curb does not exist a marker post approved by the District shall be installed within 2 feet of the valve box. Two feet of wire

shall be looped within all valve boxes. All splices to locator wire shall be made with direct bury connectors as approved by the District.

After all trench backfill operations are complete, the Contractor shall conduct (or pay for a third-party to conduct) the first conductivity test to confirm that the wire is continuous. After the installation of all other underground facilities, the Contractor shall conduct (or pay for a third-party to conduct) the second conductivity test to re-confirm that the wire is continuous. The conductivity tests shall only be performed with a District representative present. The Contractor shall be responsible for all costs to confirm, locate, and repair the breaks in the locator wire identified in the conductivity test. In addition, the Contractor shall reimburse the District for all costs to retest repaired sections of the wire. The Contractor is advised to use care in the installation and backfilling operations to prevent damage to the wire. The Contractor shall provide the District a final report summarizing the results of the conductivity testing. The report shall include but not be limited to listing points of failure identified during testing and measures taken to repair the breaks, location where tests were taken, dates, JCSD Staff present during testing, and a final summary showing all passed testing.

Splices shall be made at locations approved by the District. The wire connecting device shall be an underground electrical wire connector to splice and effectively moisture-seal the conductors. Wire connectors shall be approved by the District and shall be UL listed and CSA certified for direct burial splices.

Polyethylene Recycled Water Service Pipe (PVC Mains Only)

One (1) inch diameter polyethylene water service pipe shall only be allowed to be used under the following conditions: (1) where soil conditions are extremely corrosive to copper water service pipe, and (2) only as authorized in writing by the District.

All polyethylene pipe and tubing furnished under these specifications shall conform to all applicable requirements of the latest revision of AWWA C901. Polyethylene recycled water service pipe shall be iron pipe size and supplied by a District approved manufacturer.

The PE pipe or tubing shall be marked in accordance with ASTM D2239 for IPS pipe sizes. It shall also carry the seal of the National Sanitation Foundation (NSF).

Pressure Rating: The PE pipe and tubing shall be rated for use with water at 73.4°F at a maximum working pressure of 200 psi, based on ASTM D2837.

Dimensions: For iron pipe sizes (IPS), the standard inside dimension ratio (SIDR) shall be SIDR 7 with the average inside diameter, minimum wall thickness and respective tolerances for any cross section as specified in ASTM D2239.

Minimum Burst Pressure: The minimum burst pressure at 73.4°F determined in accordance with ASTM D1599 latest revision, shall be 630 psi. The time of testing of each specimen shall be between 60 and 70 seconds.

Sustained Pressure: The PE pipe and tubing shall not fail, balloon, burst or weep as defined in ASTM D1598, latest revision, when tested in accordance with Section 7.6 of ASTM D2239.

5. WELDED STEEL FITTINGS

All bends, reducers, increasers, tees, crosses, wyes, and other special fittings, except as specifically noted on the Drawings, shall be constructed of cement mortar lined steel pipe with coating as specified for balance of pipeline, and shall be shop fabricated in accordance with the latest revision of AWWA C208. (as modified below).

ELBOWS

Angle	0-22 1/2	22 1/2°-45°	45°-67 1/2°	67 1/2°-90°
No. Pieces	2	3	4	5

NOTE: At the break point angles (i.e. 22 1/2°, 45°, and 67 1/2°) the Contractor shall use the elbow with the largest number of pieces.

All fittings shall have a steel cylinder thickness equal to or greater than the specified wall thickness of the pipeline, but not less than 10 gauge. The minimum radius for all bends shall not be less than 2.5 times the nominal diameter of the pipelines. Where simulated weld bells are used for lap-welded fittings, the bell plate thickness shall be 1/4".

Special fittings shall be fabricated from machine cement mortar lined and machine outside coated. The individual parts of the fittings shall be cut from the pipe, welded together, and the coating and lining of shop joints shall be hand applied to provide a

finished cement mortar lined and finished outside coated joint comparable to the mechanically applied lining and coating detailed herein.

Specials and fittings fabricated from cylinders that have been hydrostatically tested in accordance with these specifications shall be tested by the dye-check method, or approved equal, prior to the lining and coating of said material. Contractor shall submit fabrication drawings for all AWWA shop fabricated fittings to the District for approval prior to construction.

Long Radius Steel Elbows

Seamless, forged long radius steel elbows shall be used where specified by the District and shall be shop fabricated in accordance with the latest revision of ASTM A234.

6. DUCTILE IRON FITTINGS

Bends, Tees, Crosses, Reducers, Bushings, Adapters, Caps, and Plugs for Ductile Iron Pipe; ANSI/AWWA C110-(latest), minimum 250 psi rated working pressure, cement mortar lining shall be "double thickness" in accordance with AWWA C104-(latest), flange ends (F) shall conform in dimensions and drilling to ANSI B16.1 for cast-iron flanges and flanged fittings for 125 lb., produced by a "District Approved Manufacturer". Short body pattern is acceptable. Properly fitting rubber gasket joint fittings are also acceptable. Fittings shall be double polyethylene encased in purple color per AWWA C105.

7. AWWA GATE VALVES

All resilient seat gate valves shall meet the requirements of AWWA C509-(latest) for rubber seated gate valves and shall be tested bubble-tight. In addition, RS Gate Valves shall be furnished with the following items:

- Valve body and bonnet shall be fusion bonded epoxy coated inside and out (10 mils nominal thickness) and meet all requirements of AWWA C550.
- Low zinc bronze stems.
- All stainless steel body hardware. Resilient seat gate valves shall be produced by a "District Approved Manufacturer".

8. RUBBER SEATED BUTTERFLY VALVES

Butterfly valves shall conform to the latest revision of AWWA C504 and the following:

- Butterfly valves and operators shall be Class 150B, constructed for direct burial and have flanged ends to mate A.S.A. 150 lb. steel flanges.
- Butterfly valves shall be furnished with operators of the traveling nut or worm gear type, self-locking in any position, and sealed, gasketed, and lubricated to withstand a submersion in water to 10 psi. The valve shall open by counter-clockwise rotation of a 2-inch square AWWA operating nut.
- The operator shall be capable of meeting the torque requirements for opening and closing the valve against:
 - 150 psi upstream and 0 psi downstream pressure.
 - Maximum inlet-outlet flow rate of 12 FPS, normal flow rate of 6 FPS, and shall be provided with AWWA stops capable of absorbing up to 300 foot-pounds of input torque without damage to the valve or operator.
- Butterfly valves shall have Buna N seat bonded or mechanically retained, without use of metal retainers or other devices located in the flow stream, to the body and have a disc seating edge of nichrome or stainless steel. All internal mountings or working parts shall be stainless steel.
- Butterfly valves shall have the shaft V-type self-adjusting packing. The shaft shall not be exposed between the valve body and the operator.
- Butterfly valves shall be furnished with records of tests specified in AWWA C504, Section 2.3 and Section 5. All valves shall be furnished with Certified drawings and parts list of the valve and operator. An affidavit of compliance to AWWA C504 shall be furnished for all valves. Five (5) sets of the above information shall be furnished to the District.

- Butterfly valves shall have their internal and external surfaces (except flange faces, stainless steel and rubber surfaces) epoxy coated, to meet all requirements of AWWA C550. All butterfly valves shall be lined (holiday free) with a minimum of 10 mils (2-5 mil coats) of Keysite 750, (white); or DeVoe Bar-Rust No. 235 (white). The epoxy lining shall be applied at the valve manufacturer's plant in accordance with the coating manufacturer's application specifications.
- Approved butterfly valves shall be produced by a "District Approved Manufacturer".

9. COPPER TUBING

Copper tubing shall conform to the requirements of the "Specifications for Seamless Copper Water Tube" (ASTM Designation B88) and shall be Type K. As required by the District, copper tubing shall be installed with a 6 mil (minimum) purple polyethylene sleeve "Polywrap C" by Northtown Company or District approved equal.

10. INSULATING UNIONS

Where dissimilar pipe materials are joined, suitable insulating unions shall be installed. Insulating unions shall be produced by a "District Approved Manufacturer".

11. PRESSURE GAUGES

Except as otherwise provided in these specifications, pressure gauges shall be 4-inch diameter dials, liquid filled, AISI 316 stainless steel case, have stainless steel elements, and 1/2-inch bottom connection. Accuracy shall be 0.5% of full scale. In all cases the normal operating pressure of the system to which the gauge is attached shall be within the middle 1/3 of the gauge range. Gauges shall read in pounds per square inch for pressure. Gauge shall be produced by a "District Approved Manufacturer."

12. PRESSURE REGULATING VALVES

A. General

Regulating valve shall be a diaphragm actuated, single seated, hydraulically operated globe-type valve. The valve body shall be ductile iron or stainless steel. It shall have two operating chambers sealed from each other by a flexible synthetic

rubber fully-supported diaphragm. The valve disc shall be resilient with a rectangular cross section and shall be retained on three sides. Valve bodies and all necessary parts shall be a size and type suitable for use with pressure as specified and include all necessary fittings for correct pilotry and connections. The model numbers shall be as indicated on the Drawings.

Regulating valves shall be subject to hydrostatic test of not less than twice the maximum pressure rating. Pressure rating (Class) shall be as indicated on the Drawings.

B. Pump Control Valves

Control of valve operation shall be by means of an externally mounted, four-way, solenoid pilot valve. Self-cleaning strainers shall be used to protect the control system. Valve shall utilize line pressure for operation. A Limit-switch shall be installed to be adjustable over entire valve travel. Valve shall be equipped with a built-in lift type check feature to prevent reverse flow. It shall operate independently of the solenoid control. Solenoid valve shall operate on 120 VAC.

C. Pressure Relief Valves

The Pressure Relief Valve shall maintain constant upstream pressure by bypassing or relieving excess pressure, and shall maintain close pressure limits without causing surges. The diaphragm assembly containing a valve stem shall be fully guided at both ends by a bearing in the valve cover and an integral bearing in the valve seat. This diaphragm assembly shall be the only moving part and shall form a sealed chamber in the upper portion of the valve, separating operating pressure from line pressure. The diaphragm shall consist of nylon fabric bonded with synthetic rubber and shall not be used as a seating surface. There shall be no pistons operating the valve or pilot controls. All necessary repairs shall be possible without removing valve from the line. The pilot control shall be a direct-acting, adjustable, spring-loaded, diaphragm valve, designed to permit flow when controlling pressure exceeds spring setting. The pilot control system shall operate such that as excess line pressure is dissipating the main valve shall gradually close to a positive, drip-tight seating.

D. Rate of Flow Control Valves

The valve shall maintain a constant rate of flow regardless of fluctuations in upstream pressure. The diaphragm assembly containing a valve stem shall be fully guided at both ends by a bearing in the valve cover and an integral bearing in the valve seat. The diaphragm assembly shall be the only moving part and shall form a sealed chamber in the upper portion of the valve, separating operating pressure from line pressure. The diaphragm shall consist of nylon fabric bonded with synthetic rubber and shall not be used as a seating surface. There shall be no pistons operating the valve or pilot controls. All necessary repairs shall be possible without removing valve from the line.

The pilot control shall be a direct-acting diaphragm valve designed to close when the actuating differential increases beyond the spring setting. The actuating differential pressure shall be produced by a thin-edge orifice plate installed in an orifice flange located downstream of the valve.

E. Pressure Reducing/Pressure Sustaining Valves

This valve shall maintain a constant downstream pressure regardless of fluctuations in demand. When the upstream pressure becomes equal to the spring setting of the pressure sustaining control, the valve throttles to maintain a constant inlet pressure. If the downstream pressure is greater than the upstream pressure the valve closes automatically to prevent return flow.

The diaphragm assembly containing a valve stem shall be fully guided at both ends by a bearing in the valve cover and an integral bearing in the valve seat. This diaphragm assembly shall be the only moving part and shall form a sealed chamber in the upper portion of the valve, separating operating pressure from line pressure. The diaphragm shall consist of nylon fabric bonded with synthetic rubber and shall not be used as a seating surface. All necessary repairs shall be possible without removing valve from the line.

The pressure reducing pilot control shall be a direct-acting, adjustable, spring-loaded, normally open diaphragm valve, which closes when downstream pressure exceeds the spring setting.

The pressure sustaining pilot control shall be a direct-acting, adjustable, spring-loaded, normally closed diaphragm valve which opens when upstream pressure exceeds the spring setting. The control system shall include a strainer orifice assembly and an adjustable opening speed control.

F. Altitude Valves

The altitude valve shall maintain a constant downstream pressure regardless of fluctuations in demand and shall also close tight when a pressure reversal occurs. It shall be a hydraulically-operated, pilot-controlled, diaphragm type globe or angle valve. The main valve shall have a single removable seat and a resilient disc. The stem shall be guided at both ends by a bearing in the valve cover and an integral bearing in the valve seat. No external packing glands are permitted, and there shall be no pistons operating the main valve or any pilot controls.

The pilot control shall be a direct-acting, adjustable, spring-loaded, normally open diaphragm valve, designed to permit flow when controlled pressure is less than the spring setting.

A system of auxiliary check valves shall be used to admit downstream pressure into the main valve cover chamber if pressure reversal occurs. This must result in positive closing of the main valve.

G. Coatings

All regulating valves shall have all wetted ferrous parts epoxy coated. The epoxy shall be thermo-setting, approved for potable water.

All coated surfaces shall be coated with 12 miles of fusion bonded epoxy and be visually and electrically examined for defects. The coating shall be holiday free with a low voltage wet sponge test per AWWA C550.

H. Options

Additional required options to be furnished with the valves shall be indicated on the Drawings utilizing the appropriate model numbers and/or catalog designations.

13. FLOW METERS

A. Service Flow Meters

Service flow meters for 5/8" through 1" diameters shall be displacement type, cold-water meters in accordance with AWWA C700, Latest; produced by a "District Approved Manufacturer". Service flow meters for 1 1/2", 2", and 3" diameters shall be turbine type cold-water meters in accordance with AWWA C701, latest; produced by a "District Approved Manufacturer". Service flow meters 4" diameter and larger shall be produced by a "District Approved Manufacturer" with all bronze turbine by-pass meter. All meters shall be equipped with Radio Reads.

Unless otherwise specified on Drawings and/or on the Bidding Sheet, subsequent to payment of fees and the purchase of the meters through the District, the District will furnish all service meters that are less than or equal to 3" diameter for installation by the Contractor. Meters 4" diameter and larger shall be furnished and installed by the Contractor in accordance with District Standards and Specifications.

The Contractor shall make all connections to the District side and private side of the meters, provide all excavation, backfill, and surface restoration, and furnish all required fittings, adapters, and piping necessary to make the connections. All costs for the work and materials shall be included in the appropriate bid items.

14. NO-OX-ID

For specified outside wrapped steel pipelines and/or where specifically directed by the District, outside pipe coating shall be NO-OX-ID special protective metal coating and wax.

15. PRECAST CONCRETE VAULTS

Refer to Basic Specifications Section B.18.

16. FUSION BONDED EPOXY COATING

Wherever fusion-bonded epoxy coating is specified on steel piping or equipment for potable water, the coating system shall consist of one coat of Scotchkote 134; Tnemec

Series 104 or District approved equal. Minimum dry film thickness shall be 12.0 mils. Surface preparation shall be SSPC-10. Coating shall be in accordance with NSF-61. Method of application shall be electrostatic spray method heat fusion per coating manufacturer's specifications.

Submit manufacturer's data sheets for review and approval, including: method of application; minimum and maximum DFT; recommended surface preparation; application instructions and curing requirements; etc.

17. PIPE SUPPORTS

Pipe supports shall be adjustable for pipeline products PSG series pipe supports or District approved equal. Pipe support shall be painted with primer and two (2) coats of purple paint per District specifications. The pipe and saddle shall be separated by 1/8" thick Neoprene Rubber.

18. VALVE BOXES

All valve boxes and valve covers installed within a recycled water system shall be purple in color, Pantone 522C.

19. WARNING SIGNS, LABELS AND TAPE

Warning signs and labels shall be attached to all above ground recycled water facilities. Signs and labels shall be purple in color, Pantone 522C, with black lettering, and shall read "CAUTION: RECYCLED WATER – DO NOT DRINK."

Warning signs must be visible to public in a size no less than 8.5 inches high by 11 inches wide. Sign material shall be 5052-H38 Alodized/Anodized Aluminum (thickness = 0.80 inches). Post must be set in concrete. Signs should be constructed per District Standard Drawing No. R/NP-17.

The District requires warning labels to be installed on all recycled water appurtenances above grade and in vaults, such as but not limited to, air release valves, blow-offs, pumps and meters.

Warning tape shall be installed 3 inches above the top center and shall run continuously for the entire length of all constant pressure main line piping. Warning tape shall be purple plastic with black printing having the words "CAUTION: RECYCLED

WATER OR NON-POTABLE WATER – DO NOT DRINK” imprinted in minimum 1-inch high letters. Imprinting shall be continuous and permanent. The overall width shall be a minimum of 3 inches.